

General Contractors

M.A. & M., Inc.
dba **ARESCO**
CONSTRUCTION
COMPANY

175 North Main Street
Middletown, CT 06457
Phone (860) 346-6621
Fax (860) 344-8236

RCO - Request for Change

Middletown Senior/Community Center Sept. 30, 2014

RCO # 033


Silver /Petrucci & Associates
3190 Whitney Highway
Hamden, CT 06518
Attn: Mr. Steven June


Description: Kiln transformer

The following is our cost to furnish and install a new kiln room transformer as detailed in SK-E3.

Subcontractor	\$3,593
GC	\$359
Bond	\$ 59
Total RCO 33	\$4,012

Sincerely,


Joseph D. Aresco
President



KILN ROOM 216

SCALE: 1/4" = 1'-0"

DRAWING KEY NOTES

- ① PROPOSED LOCATION FOR BUCK & BOOST TRANSFORMER RATED FOR 25KVA, 120/208V-240V. COORDINATE MOUNTING LOCATION IN THE FIELD AND PROVIDE ALL COMPONENTS NECESSARY FOR A COMPLETE MANUFACTURER APPROVED INSTALLATION, INCLUDING GROUND TO BUILDING STEEL.
- ② PROVIDE 150A-2P C/B, 1-1/2"C, 3#1/0, 1#8G TO SUIT BOOST TRANSFORMER PRIMARY CONNECTION.
- ③ PROVIDE: 3#2, 1#8G IN RACEWAY. CONTRACTOR SHALL TAP FEEDER WITHIN RACEWAY TO SUIT DISCONNECT/ENCLOSURE BREAKER. TAP FEEDER AS PER NEC-2011 REQUIREMENTS. PROVIDE ALL COMPONENTS NECESSARY FOR A COMPLETE NEC-2011 APPROVED INSTALLATION.
- ④ PROVIDE: 1"C, 3#6, 1#10G TO SUIT DISCONNECT/ENCLOSURE BREAKER.
- ⑤ PROVIDE 60A-2P FUSED DISCONNECT SWITCH OR ENCLOSED CIRCUIT BREAKER. COORDINATE MOUNTING LOCATION IN THE FIELD AND CLEARANCE AS PER NEC REQUIREMENTS. TYPICAL OF 2.
- ⑥ DEDICATED NEMA RECEPTACLE TO SUIT KILN UNIT RATED FOR 240V. COORDINATE CONNECTION REQUIREMENT WITH EXISTING EQUIPMENT IN THE FIELD.

MIDDLETOWN SENIOR /
COMMUNITY CENTER
61 Durant Terrace
Middletown, Connecticut 06457



SILVER /
PETRUCELLI +
ASSOCIATES
An Electrical Engineers Interior Designer
1190 Tappan Avenue, Hamden, CT 06518-2340
Tel: 203 340 9007 Fax: 203 240 6247
silverpetrucelli.com

KILN ROOM 216

09/17/14

1/4" = 1'-0"

JRP

11.134

SK
E-3



175 Main Street
 Rockfall, CT 06481
 860 343 0467 Telephone
 860 343 1572 Fax
 electricworksinc.biz

PROPOSAL FOR CHANGE ORDER

PROJECT AUTHORIZATION # 001

We are a Certified Small Business Enterprise for the State of Connecticut Small Contractors Set-Aside Program.

TO:
MA+M Construction
175 Main St.
Middletown CT.06457

PHONE	DATE
860-346-6621	30-Sep-14
JOB NAME / LOCATION	
Middletown Senior Center	
Kiln Feeder	

We hereby agree to make the change(s) specified below:

Install buck Boost Transformer and feeder for the new Liln in Room 216
 and as per drawinf SK-E3.
 the Buck Boost transformer will by 5 KVA and good for 135 anps.

2 pole 150 breaker \$389

Wire , fittings misc materials \$100

5 KVA Buck Boost Transformer, \$985

2 two pole 60 amp fuss disc. With fusses \$240

2 50 amp outlets \$50

Labor 2 men 8 hr. at \$85?hr = \$1,360

Sub total \$3,124

15% P+O

TOTAL \$3,593

NOTE: This Change Order becomes part of and in conformance with the existing contract.

WE AGREE hereby to make the change(s) specified above at this price:			00
DATE	PREVIOUS CONTRACT AMOUNT:		
AUTHORIZED SIGNATURE (CONTRACTOR)	REVISED CONTRACT TOTAL:		

ACCEPTED -- The above prices and specifications of this Change Order are satisfactory and are hereby accepted. All work to be performed under same terms and conditions as specified in original contract unless otherwise stipulated.

Date of acceptance: _____

Official signature: _____

