

✓

**REVISED**

**LEAD INSPECTION**

**PERFORMED AT:**

**NORTH END PROJECT PHASE 1 - FERRY STREET BUILDINGS  
MIDDLETOWN, CT**

**PREPARED FOR:**

**PAMELA MIKUS  
VICE PRESIDENT  
THE RICHMAN GROUP DEVELOPMENT CORPORATION  
340 PEMBERWICK ROAD  
GREENWICH, CT 06831**

**PREPARED BY:**

**AMC TECHNOLOGY INC.  
P. O. BOX 413  
STRATFORD, CONNECTICUT 06615  
(203) 378-5020**

**Inspection Date: September 1, 6, 9 & 12, 2005  
Report Date: September 15, 2005**

## **1.0 EXECUTIVE SUMMARY**

On September 1, 6, 9 & 12, 2005, AMC Technology, Inc. tested representative interior and exterior building components for the presence of lead-based paint at North End Project Phase 1 - Ferry Street Buildings, Middletown, Connecticut. The inspection included the buildings located at 34, 40, 54, 56 (Rear Building/Bakery), 58, 60, 64 and 66 Ferry Street, Middletown, Connecticut. The purpose of this inspection was to identify lead-based paint on building components scheduled for demolition.

Below you will find background information concerning lead based paint and a summary of our findings. Included are regulatory issues that relate to lead based paint and instructions on how to interpret the **X-ray Fluorescence Analyzer (XRF)** results.

## **2.0 BACKGROUND INFORMATION CONCERNING LEAD-BASED PAINT**

Toxic level lead-based paint as defined by the State of Connecticut Lead Poisoning and Control Regulations (19a-111-1 through 19a-111-11) means a level of lead which when present in a dried paint, plaster or other accessible surface in a residential dwelling contains greater than or equal to 0.50 percent lead by dry weight as measured by atomic absorption spectrophotometry (AAS), or 1.0 milligrams lead per square centimeter of surface as measured on site by an X-ray fluorescence analyzer or other equipment deemed sufficiently accurate and reliable by the commissioner. OSHA Regulations including but not limited to 29 CFR 1926.62 consider any amount of lead in paint (above or below Connecticut's level) to be a concern. The State of Connecticut, Department of Environmental Protection has issued "Guidance for the Management and Disposal of Lead-Contaminated Materials Generated in the Lead Abatement, Renovation, and Demolition Industries" dated November 4, 1994 and revised October 18, 1996. It requires "lead-containing debris not contaminated with other hazardous wastes is either classified as hazardous waste or solid waste, depending on its lead content. The required analytical test to determine which of these classifications is appropriate for a given quantity of lead-containing debris is the Toxicity Characteristic Leaching Procedure, or "TCLP" (Regulations of Connecticut State Agencies Section 22a-449c - 101 (a) (1), incorporating 40 CFR 262.24). The TCLP test subjects a 100-gram sample of a waste material to simulated landfill leaching conditions, and assesses the ability of the sample to leach out lead in this environment. The debris is classified as hazardous waste if the TCLP sample result is greater than or equal to 5.0 milligrams per liter (mg/l) of lead. The debris is classified as solid waste if the TCLP sample result is less than 5.0 mg/l."

The X-ray Fluorescence Analyzer (XRF) is the most common and accepted means of field testing for lead in paint. Atomic absorption spectrometry (AAS) is used for paint chip samples in the laboratory. (Note: The State of Connecticut does not recognize sodium sulfide (Na<sub>2</sub>S) as negative declaration of lead content), although it may be used as a positive indicator of lead in paint.

XRF detects lead through gamma ray technology. It is designed to measure the total weight of lead in a measured area. The results are reported in milligrams per square centimeter (mg/cm<sup>2</sup>). The equipment used during this inspection was an RMD Model LPA-1, XRF Analyzer, Serial No. 01326.

### 3.0 SUMMARY OF TOXIC LEVEL LEAD PAINT SURVEY RESULTS

The following areas were found to contain a toxic level of lead based paint ( $\geq 1.0\text{mg/cm}^2$ ):

#### 36 FERRY STREET (Field Card Location 34 Ferry Street, Lot #29)

Sample #	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
3	Apartment 2E Living Room	C	White	Exterior Door Casing	Wood	Poor	>9.9	+
22	Exterior	D	Gray	Window Casing	Wood	Poor	6.9	+ Basement

#### 40 FERRY STREET (Field Card Location 40 Ferry Street, Lot #30)

Sample #	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
21	Exterior	B	White	Window Casing	Wood	Poor	>9.9	+

#### 56 FERRY STREET (Field Card Location 54 Ferry Street, Lot #34)

Sample #	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
29	Front Building Unit 1 Room 3	B	Gray	Wall	Plaster	Poor	4.6	+
37	Front Building Unit 1 Room 5	D	White	Window Sash	Wood	Poor	3.2	+
38	Front Building Unit 1 Room 5	D	White	Window Sash	Wood	Poor	2.8	+

**56 FERRY STREET (Field Card Location 54 Ferry Street, Lot #34)**

Sample #	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
39	Front Building Unit 1 Room 5	D	White	Window Trim	Wood	Poor	2.0	+
44	Front Building Unit 1 Room 5	A	Brown	Door Frame	Wood	Poor	1.9	+
7	Front Building Unit 2 Room 1	B	Beige	Window Well	Wood	Poor	>9.9	+
23	Front Building Unit 2 Bathroom	B	White	Window Sash	Wood	Poor	2.3	+
24	Front Building Unit 2 Bathroom	D	White	Door Casing	Wood	Fair	1.0	+
33	Front Building Unit 2 Room 4	C	Red	Window Well	Wood	Poor	2.0	+
13	Exterior	D	White	Window Casing	Wood	Poor	4.9	+ Front
14	Exterior	D	Green	Window Sash	Wood	Poor	1.6	+ Front
19	Exterior	D	Green	Siding	Wood	Intact	1.3	+ Front
20	Exterior	D	Green	Porch Wall	Wood	Intact	1.4	+ Front
21	Exterior	D	White	Wall	Wood	Poor	3.1	+ Front

**56 FERRY STREET (Rear Building/Bakery, Field Card Location 56 Ferry Street, Lot #33)**

Sample #	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
15	Rear Bldg./ Bakery Bakery Unit Bathroom	D	Blue	Door	Wood	Fair	2.3	+

**56 FERRY STREET (Rear Building/Bakery, Field Card Location 56 Ferry Street, Lot #33)**

Sample #	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
16	Rear Bldg./ Bakery Bakery Unit Bathroom	C	Blue	Wall	Brick	Poor	1.0	+
3	Rear Bldg./ Bakery Unit 1 Room 1	D	White	Door Jamb	Wood	Poor	2.3	+
6	Rear Bldg./ Bakery Unit 1 Room 1	D	Beige	Window Sash	Wood	Poor	1.0	+
7	Rear Bldg./ Bakery Unit 1 Room 1	D	Beige	Window Well	Wood	Poor	1.0	+
12	Rear Bldg./ Bakery Unit 1 Room 2	A	White	Window Sash	Wood	Poor	2.8	+
20	Rear Bldg./ Bakery Unit 1 Room 3	B	White	Window Well	Wood	Poor	6.2	+
25	Rear Bldg./ Bakery Unit 1 Bathroom	B	White	Window Well	Wood	Poor	5.7	+
29	Rear Bldg./ Bakery Unit 1 Room 4	D	Yellow	Window Well	Wood	Poor	2.9	+
1	Rear Bldg./ Bakery Unit 2 Room 1	D	White	Window Well	Wood	Poor	2.3	+
2	Rear Bldg./ Bakery Unit 2 Room 1	D	White	Window Sash	Wood	Poor	3.8	+
3	Rear Bldg./ Bakery Unit 2 Room 1	D	Gray	Ceiling	Plaster	Poor	1.0	+
4	Rear Bldg./ Bakery Unit 2 Room 1	A	Green	Wall	Plaster	Poor	3.5	+

**56 FERRY STREET (Rear Building/Bakery, Field Card Location 56 Ferry Street, Lot #33)**

Sample #	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
8	Rear Bldg./ Bakery Unit 2 Room 2	A	White	Window Well	Wood	Poor	1.8	+
9	Rear Bldg./ Bakery Unit 2 Room 2	A	White	Window Sash	Wood	Poor	2.8	+
14	Rear Bldg./ Bakery Unit 2 Room 3	B	White	Window Well	Wood	Poor	3.5	+
23	Rear Bldg./ Bakery Unit 4 Bathroom	B	White	Window Well	Wood	Poor	2.2	+
29	Rear Bldg./ Bakery Unit 4 Room 4	D	White	Window Well	Wood	Poor	4.1	+
24	Exterior	D	White	Window Casing	Wood	Poor	1.6	+ Rear
27	Exterior	A	White	Window Sill	Wood	Poor	4.3	+ Rear

**58 FERRY STREET (Field Card Location 58 Ferry Street, Lot #33)**

Sample #	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
6	2 <sup>nd</sup> Floor Front Apt. Dining Room	B	White	Door	Wood	Intact	8.3	+
7	2 <sup>nd</sup> Floor Front Apt. Dining Room	B	White	Door Casing	Wood	Intact	>9.9	+
8	2 <sup>nd</sup> Floor Front Apt. Dining Room	B	White	Baseboard	Wood	Intact	>9.9	+
10	2 <sup>nd</sup> Floor Front Apt. Kitchen	D	White	Door	Wood	Intact	>9.9	+
11	2 <sup>nd</sup> Floor Front Apt. Kitchen	D	White	Door Casing	Wood	Intact	>9.9	+

**58 FERRY STREET (Field Card Location 58 Ferry Street, Lot #33)**

Sample #	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
12	2 <sup>nd</sup> Floor Front Apt. Kitchen	D	White	Window Casing	Wood	Intact	>9.9	+
15	2 <sup>nd</sup> Floor Front Apt. Bedroom 2	A	Blue	Wall	Plaster	Intact	4.6	+
16	2 <sup>nd</sup> Floor Front Apt. Bedroom 2	A	White	Door Casing	Wood	Intact	7.1	+
18	2 <sup>nd</sup> Floor Front Apt. Bedroom 1	B	Purple	Wall	Plaster	Intact	5.6	+
30	Exterior	A	White	Door Lintel	Metal	Intact	3.1	+
4	Exterior	B	Tan	Siding	Wood	Intact	>9.9	+
5	Exterior	B	Tan	Window Casing	Wood	Intact	1.0	+
6	Exterior	B	Green	Window Casing	Wood	Poor	2.6	+
8	2 <sup>nd</sup> Floor Rear Apt. Kitchen	A	White	Wall	Plaster	Intact	2.6	+
11	2 <sup>nd</sup> Floor Rear Apt. Dining Rm.	D	White	Baseboard	Wood	Intact	>9.9	+
12	2 <sup>nd</sup> Floor Rear Apt. Bathroom	B	White	Door	Wood	Intact	>9.9	+
13	2 <sup>nd</sup> Floor Rear Apt. Bathroom	B	White	Door Casing	Wood	Intact	>9.9	+

**60 FERRY STREET (Field Card Location 60 Ferry Street, Lot #36)**

Sample #	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
1	2 <sup>nd</sup> Floor Front Apt Room 1	A	Blue	Wall	Plaster	Intact	1.1	+
5	2 <sup>nd</sup> Floor Front Apt Room 1	-	White	Ceiling	Plaster	Intact	1.0	+
9	2 <sup>nd</sup> Floor Front Apt Room 2	D	White	Door	Wood	Poor	>9.9	+

**60 FERRY STREET (Field Card Location 60 Ferry Street, Lot #36)**

Sample #	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
15	2 <sup>nd</sup> Floor Front Apt Room 3	C	White	Door	Wood	Intact	>9.9	+
16	2 <sup>nd</sup> Floor Front Apt Kitchen	D	White	Wall	Plaster	Intact	7.0	+
19	2 <sup>nd</sup> Floor Front Apt Bathroom	C	Tan	Wall	Plaster	Intact	1.7	+
20	2 <sup>nd</sup> Floor Front Apt Attic	C	White	Wall	Wood	Intact	6.2	+
23	Exterior	D	White	Siding	Wood	Poor	>9.9	+ under siding
25	Exterior	D	Brown	Window Frame	Wood	Poor	4.6	+
29	Exterior	C	White	Siding	Wood	Poor	>9.9	+
30	Exterior	D	Brown	Window Frame	Wood	Poor	3.2	+
32	Exterior	D	White	Door Casing	Wood	Poor	2.1	+
35	Exterior	D	White	Window Casing	Wood	Poor	6.1	+
38	Exterior	A	White	Window Sill	Wood	Poor	>9.9	+

**64 FERRY STREET (Field Card Location 66 Ferry Street, Lot #37A)**

Sample #	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
4	Storage Room	A	Light Blue	Door	Wood	Intact	4.6	+
5	Storage Room	D	White	Wall	Wood	Intact	>9.9	+
7	Storage Room	A	Green	Window Frame	Metal	Poor	>9.9	+
8	Bathroom	A	Light Blue	Door	Wood	Poor	>9.9	+
11	Break Room	D	Green	Door Casing	Wood	Poor	>9.9	+
12	Break Room	D	Blue	Door	Wood	Poor	4.6	+

**66 FERRY STREET (Field Card Location 64 Ferry Street, Lot #37)**

Sample #	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
2	Exterior	A	White	Window Casing	Wood	Poor	2.6	+
5	Exterior	B	White	Window Sash	Wood	Poor	1.4	+

Please refer to Appendix A – XRF Readings for a listing of all XRF survey results. To read the inspection report, identify the area by way of building side. Letter A, B, C or D identifies each surface. These letters correspond to the side of the building on which the surface is situated. A is the front side of the building, B, C and D then continue clockwise around the building. Please refer to Appendix B – Diagrams for lead inspection diagrams. Paint condition is rated as Intact, Fair or Poor. Paint condition is rated as Intact when the entire interior or exterior painted surface is intact. Paint condition is rated as Fair when exterior components with large surface areas have less than or equal to 10 ft<sup>2</sup> of deteriorated paint, when interior components with large surface areas (i.e. walls) have less than or equal to 2 ft<sup>2</sup> of deteriorated paint and when interior and exterior components with small surface areas (i.e. baseboards) have less than or equal to 10% paint deterioration of the total surface area of the component. Paint condition is rated as Poor when exterior components with large surface areas have greater than 10 ft<sup>2</sup> of deteriorated paint, when interior components with large surface areas (i.e. walls) have greater than 2 ft<sup>2</sup> of deteriorated paint and when interior and exterior components with small surface areas (i.e. baseboards) have greater than 10% paint deterioration of the total surface area of the component.

**4.0 GENERAL STATEMENTS CONCERNING TOXIC LEVEL LEAD PAINT**


Toxic Level Lead Paint Removal from the substrate or on the substrate is subject to State and Federal Waste Disposal Regulations.

During renovation or demolition, all applicable Federal, State, worker protection regulations (OSHA 1926.62), disposal requirements (TCLP testing) and local health department requirements must be adhered to.

**5.0 DISCLAIMER**

AMC Technology, Inc. was employed to complete a representative testing of toxic levels of lead in painted surfaces. AMC Technology, Inc. makes no guarantee that surfaces not tested do not contain toxic levels of lead. Also, due to variability when applying paint coats with a brush, roller, etc., surfaces may have tested below toxic levels of lead in one area of the component but have toxic levels of lead in other areas of the component not tested.

Report Written By:

A handwritten signature in black ink, appearing to read "D. T. Kohl", written over a horizontal line.

David T. Kohl  
Connecticut Lead Inspector/Risk Assessor  
License #002112

**APPENDIX A**

**XRF SAMPLE RESULTS**

**LEAD INSPECTION DATA PAGE**

NOTES:

Drawing NOT TO SCALE

ADDRESS 36 Ferry Street (Field Card Location  
34 Ferry Street, Lot # 29)  
Middletown, CT  
Unit 1E

DATE September 6, 2005

Sample Number	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
1	Bedroom 1	C	White	Window Sash	Wood	Intact	-0.2	
2	Bedroom 1	C	White	Window Casing	Wood	Intact	-0.2	
3	Bedroom 1	C	White	Wall	Wallboard	Intact	-0.1	
4	Bedroom 1	C	White	Baseboard	Wood	Intact	-0.1	
5	Bedroom 1	-	White	Ceiling	Wallboard	Intact	0.00	
6	Bedroom 1	-	Stained	Floor	Wood	Intact	-0.2	
7	Kitchen	D	White	Door	Wood	Intact	-0.2	
8	Bathroom	B	White	Wall	Wallboard	Intact	0.2	
9	Bathroom	A	White	Door	Wood	Intact	0.1	
10	Bathroom	A	White	Door Casing	Wood	Intact	-0.00	
11	Living Room	D	White	Wall	Wallboard	Intact	-0.1	
12	Living Room	A	White	Door	Metal	Intact	0.2	
13	Den	A	White	Door	Wood	Intact	-0.2	
14	Den	A	White	Door Casing	Wood	Intact	0.00	
15	Den	D	White	Radiator	Metal	Intact	-0.1	

+ = positive for lead



**LEAD INSPECTION DATA PAGE**

NOTES:

Drawing NOT TO SCALE

ADDRESS 36 Ferry Street (Field Card Location  
34 Ferry Street, Lot # 29)  
Middletown, CT  
Apartment 2E

DATE September 6, 2005

Sample Number	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
1	Living Room	C	White	Door	Wood	Intact	0.10	
2	Living Room	C	White	Door Casing	Wood	Intact	-0.1	
3	Living Room	C	White	Exterior Door Casing	Wood	Poor	>9.9	+
4	Living Room	-	White	Ceiling	Wallboard	Intact	0.00	
5	Living Room	D	Tan	Wall	Plaster	Intact	-0.1	
6	Living Room	A	White	Door	Wood	Intact	0.1	
7	Living Room	A	White	Door Casing	Wood	Intact	0.2	
8	Kitchen	A	White	Door	Wood	Intact	-0.1	
9	Kitchen	B	Tan	Wall	Plaster	Intact	-0.2	
10	Kitchen	A	White	Baseboard	Wood	Intact	0.00	
11	Kitchen	D	Brown	Window Casing	Wood	Intact	-0.00	
12	Bathroom	D	White	Window Sash	Wood	Intact	-0.1	
13	Bathroom	D	White	Window Will	Wood	Intact	-0.2	
14	Bedroom 1	-	White	Ceiling	Wallboard	Intact	-0.1	
15	Bedroom 1	B	Tan	Wall	Plaster	Intact	-0.2	

+ = positive for lead



**LEAD INSPECTION DATA PAGE**

NOTES:

Drawing NOT TO SCALE

ADDRESS 36 Ferry Street (Field Card Location  
34 Ferry Street, Lot # 29)  
Middletown, CT  
Apartment 2W

DATE September 6, 2005

Sample Number	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
1	Bedroom 2	A	White	Window Sill	Wood	Intact	-0.1	
2	Bedroom 2	A	White	Window Sash	Wood	Intact	-0.1	
3	Bedroom 2	B	White	Wall	Wallboard	Intact	0.00	
4	Bedroom 2	-	White	Ceiling	Wallboard	Intact	0.1	
5	Bedroom 2	C	White	Door Casing	Wood	Intact	-0.5	
6	Bedroom 2	C	White	Door	Wood	Intact	-0.2	
7	Living Room	B	White	Window Casing	Wood	Intact	0.1	
8	Living Room	B	White	Wall	Wallboard	Intact	-0.1	
9	Living Room	-	White	Ceiling	Wallboard	Intact	-0.1	
10	Kitchen	A	White	Door	Wood	Intact	-0.1	
11	Kitchen	A	White	Door Casing	Wood	Intact	-0.2	
12	Bathroom	B	White	Window Sash	Wood	Intact	-0.1	
13	Bathroom	B	White	Window Casing	Wood	Intact	-0.1	
14	Bathroom	D	White	Radiator	Metal	Intact	0.1	
15	Bathroom	D	White	Wall	Wallboard	Intact	0.1	

+ = positive for lead

**LEAD INSPECTION DATA PAGE**

NOTES:

Drawing NOT TO SCALE

ADDRESS 36 Ferry Street (Field Card Location  
34 Ferry Street, Lot # 29)  
Middletown, CT  
Apartment 2W

DATE September 6, 2005

Sample Number	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
16	Bathroom	A	Gray	Threshold	Wood	Poor	0.00	
17	Bedroom 1	C	White	Door	Wood	Intact	-0.1	
18	Bedroom 1	C	White	Baseboard	Wood	Intact	-0.1	
19	Bedroom 1	-	Stained	Floor	Wood	Intact	0.00	
20	Bedroom 1	A	Black	Threshold	Rubber	Poor	-0.5	
21	Calibration						1.0	
22	Calibration						1.0	
23	Calibration						0.9	

+ = positive for lead

**LEAD INSPECTION DATA PAGE**

NOTES:

Drawing NOT TO SCALE

ADDRESS 36 Ferry Street (Field Card Location  
34 Ferry Street, Lot # 29)  
Middletown, CT  
Apartment 3W

DATE September 6, 2005

Sample Number	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
1	Bedroom	C	White	Door	Wood	Intact	0.3	
2	Bedroom	C	White	Door Casing	Wood	Intact	0.2	
3	Bedroom	C	White	Wall	Wallboard	Poor	-0.2	
4	Bedroom	-	White	Ceiling	Wallboard	Intact	0.00	
5	Bedroom	-	Stained	Floor	Wood	Intact	-0.2	
6	Bedroom	B	White	Radiator	Metal	Intact	-0.2	
7	Bedroom	B	Window Casing	White	Wood	Intact	0.2	
8	Bedroom	B	Window Sash	White	Wood	Intact	0.1	
9	Hall	C	White	Wall	Wallboard	Intact	0.2	
10	Hall	C	White	Baseboard	Wood	Intact	-0.1	
11	Hall	B	White	Door	Wood	Intact	-0.1	
12	Kitchen	B	White	Wall	Wallboard	Intact	-0.3	
13	Kitchen	B	White	Window Casing	Wood	Intact	-0.2	
14	Kitchen	A	White	Baseboard	Wood	Intact	-0.00	
15	Bathroom	A	White	Wall	Plaster	Intact	-0.2	

+ = positive for lead



**LEAD INSPECTION DATA PAGE**

NOTES:

Drawing NOT TO SCALE

ADDRESS 36 Ferry Street (Field Card Location)  
34 Ferry Street, Lot # 29  
Middletown, CT  
Common Areas

DATE September 6, 2005

Sample Number	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
1	Calibration						0.9	
2	Calibration						0.9	
3	Calibration						0.9	
4	1 <sup>st</sup> Floor Hall	D	White	Wall	Wallboard	Intact	-0.1	
5	1 <sup>st</sup> Floor Hall	D	White	Baseboard	Wood	Intact	0.1	
6	1 <sup>st</sup> Floor Hall	C	Brown	Tread	Wood	Poor	-0.1	
7	1 <sup>st</sup> Floor Hall	C	Brown	Riser	Wood	Intact	-0.00	
8	1 <sup>st</sup> Floor Hall	D	Brown	Rail	Metal	Poor	-0.2	
9	1 <sup>st</sup> Floor Hall	D	Brown	Stringer	Wood	Intact	0.00	
10	1 <sup>st</sup> Floor Hall	-	White	Ceiling	Wallboard	Intact	0.1	
11	2 <sup>nd</sup> Floor Stairwell	D	Brown	Baseboard	Wood	Intact	-0.2	
12	2 <sup>nd</sup> Floor Stairwell	C	Gray	Door	Wood	Poor	-0.1	
13	Exterior	A	White	Door	Wood	Poor	-0.2	
14	Exterior	A	White	Door Casing	Wood	Poor	-0.1	
15	Exterior	A	Black	Rail	Metal	Poor	-0.1	

+ = positive for lead

**LEAD INSPECTION DATA PAGE**

NOTES:

Drawing NOT TO SCALE

ADDRESS 36 Ferry Street (Field Card Location  
34 Ferry Street, Lot # 29)  
Middletown, CT  
Common Areas

DATE September 6, 2005

Sample Number	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
16	Exterior	A	White	Window Sill	Metal	Intact	-0.00	
17	Exterior	A	White	Siding	Vinyl	Intact	-0.1	
18	Exterior	C	White	Siding	Vinyl	Intact	-0.3	
19	Exterior	C	White	Door	Wood	Poor	-0.1	
20	Exterior	D	Brown	Door	Wood	Intact	-0.1	
21	Exterior	D	Brown	Door Casing	Wood	Intact	0.00	
22	Exterior	D	Gray	Window Casing	Wood	Poor	6.9	+ Basement
23	Exterior	D	Brown	Window Frame	Metal	Intact	-0.1	

+ = positive for lead

## LEAD INSPECTION DATA PAGE

Page 1 of 2

NOTES:

Drawing NOT TO SCALE

ADDRESS 40 Ferry Street (Field Card Location  
40 Ferry Street, Lot # 30)  
Middletown, CT  
Unit 1

DATE September 6, 2005

Sample Number	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
1	Calibration						0.9	
2	Calibration						0.9	
3	Calibration						1.0	
4	Kitchen	B	White	Wall	Wallboard	Intact	-0.00	
5	Kitchen	B	White	Radiator	Metal	Intact	-0.4	
6	Kitchen	B	White	Window Sill	Wood	Intact	-0.00	
7	Kitchen	B	White	Window Sill	Wood	Intact	-0.4	
8	Kitchen	B	White	Window Sash	Metal	Intact	-0.1	
9	Kitchen	-	White	Ceiling	Wallboard	Intact	-0.4	
10	Living Room	C	White	Door Casing	Wood	Intact	-0.1	
11	Living Room	-	White	Ceiling	Wallboard	Intact	-0.2	
12	Bathroom	B	White	Wall	Wallboard	Intact	0.1	
13	Bathroom	B	Gray	Radiator	Metal	Intact	-0.2	
14	Bathroom	A	White	Door Casing	Wood	Intact	-0.1	
15	Living Room	A	White	Door	Metal	Intact	0.00	

+ = positive for lead



**LEAD INSPECTION DATA PAGE**

NOTES:

Drawing NOT TO SCALE

ADDRESS 40 Ferry Street (Field Card Location  
40 Ferry Street, Lot # 30)  
Middletown, CT  
Unit 4

DATE September 6, 2005

Sample Number	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
1	Bedroom 1	D	Gray	Door	Metal	Intact	-0.1	
2	Bedroom 1	D	Gray	Door Casing	Wood	Intact	-0.1	
3	Bedroom 1	A	White	Wall	Plaster	Intact	-0.2	
4	Bedroom 1	A	Gray	Baseboard	Rubber	Intact	0.1	
5	Bedroom 1	A	White	Radiator	Metal	Intact	0.0	
6	Bedroom 1	A	Gray	Window Sash	Wood	Poor	0.00	
7	Bedroom 1	-	White	Ceiling	Wallboard	Intact	-0.1	
8	Bedroom 2	-	White	Ceiling	Wallboard	Intact	-0.2	
9	Bedroom 2	A	Gray	Window Casing	Wood	Intact	0.00	
10	Bedroom 2	D	White	Door	Wood	Intact	-0.2	
11	Bedroom 3	C	White	Wall	Plaster	Intact	-0.3	
12	Bedroom 3	-	White	Ceiling	Wallboard	Intact	-0.1	
13	Bedroom 3	D	White	Door Casing	Wood	Intact	-0.4	
14	Kitchen	C	White	Baseboard	Rubber	Intact	0.1	
15	Kitchen	C	White	Door	Metal	Intact	-0.2	

+ = positive for lead



**LEAD INSPECTION DATA PAGE**

NOTES:

Drawing NOT TO SCALE

<b>ADDRESS</b> 40 Ferry Street (Field Card Location 40 Ferry Street, Lot # 30) Middletown, CT Unit 5	<b>DATE</b> September 6, 2005
---	-------------------------------

Sample Number	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
1	Kitchen	C	White	Door	Metal	Intact	-0.1	
2	Kitchen	C	White	Door Casing	Wood	Intact	0.1	
3	Kitchen	B	White	Wall	Wallboard	Intact	-0.2	
4	Kitchen	-	White	Ceiling	Wallboard	Intact	-0.1	
5	Kitchen	C	White	Radiator	Metal	Intact	0.1	
6	Kitchen	D	Black	Baseboard	Rubber	Intact	0.2	
7	Bedroom 2	C	White	Wall	Wallboard	Intact	-0.1	
8	Bedroom 2	C	White	Window Casing	Wood	Intact	0.1	
9	Bathroom	B	White	Wall	Wallboard	Intact	-0.3	
10	Bathroom	-	White	Ceiling	Wallboard	Intact	-0.1	
11	Bathroom	B	Gray	Baseboard	Rubber	Intact	0.00	
12	Bedroom 1	D	White	Door	Wood	Intact	-0.4	
13	Bedroom 1	D	White	Door Casing	Wood	Intact	-0.1	
14	Living Room	B	White	Door	Metal	Intact	-0.2	
15	Living Room	A	White	Window Sill	Wood	Intact	-0.3	

+ = positive for lead

**LEAD INSPECTION DATA PAGE**

NOTES:

Drawing NOT TO SCALE

ADDRESS 40 Ferry Street (Field Card Location  
40 Ferry Street, Lot # 30)  
Middletown, CT  
Unit 8

DATE September 6, 2005

Sample Number	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
1	Bathroom	C	White	Wall	Wallboard	Intact	0.00	
2	Bathroom	C	Brown	Baseboard	Rubber	Intact	0.1	
3	Bathroom	-	White	Ceiling	Wallboard	Intact	-0.1	
4	Bathroom	C	Stained	Door	Wood	Intact	0.2	
5	Living Room	B	Red	Door	Metal	Poor	0.00	
6	Living Room	B	Brown	Stained	Metal	Intact	0.1	
7	Living Room Closet	A	Tan	Wall	Wallboard	Intact	-0.00	
8	Living Room Closet	B	Tan	Shelf	Wood	Intact	0.20	
9	Living Room Closet	B	Gray	Door Casing	Wood	Intact	-0.1	
10	Bedroom 1	B	Tan	Door	Wood	Intact	-0.1	
11	Bedroom 1	B	White	Door Casing	Wood	Intact	0.00	
12	Bedroom 1	A	Tan	Wall	Wallboard	Intact	0.00	
13	Bedroom 1	-	White	Ceiling	Wallboard	Intact	-0.3	
14	Bedroom 1	D	Gray	Window Sill	Wood	Poor	0.00	
15	Bedroom 1	D	Gray	Window Casing	Wood	Intact	0.00	

+ = positive for lead



## LEAD INSPECTION DATA PAGE

Page 1 of 1

NOTES:

Drawing NOT TO SCALE

ADDRESS 40 Ferry Street (Field Card Location  
40 Ferry Street, Lot # 30)  
Middletown, CT  
Unit 9

DATE September 6, 2005

Sample Number	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
1	Calibration						0.9	
2	Calibration						0.9	
3	Calibration						0.9	
4	Kitchen	B	Blue	Wall	Wallboard	Intact	-0.1	
5	Living Room	D	White	Wall	Wallboard	Intact	-0.1	
6	Bedroom 2	D	White	Door	Wood	Intact	0.1	
7	Bedroom 2	D	White	Door Casing	Wood	Intact	0.1	
8	Bedroom 2	-	White	Ceiling	Wallboard	Intact	-0.1	
9	Bedroom 1	B	White	Window Casing	Wood	Intact	-0.1	
10	Bedroom 1	A	White	Baseboard	Wood	Intact	0.1	
11	Bedroom 1	-	White	Ceiling	Wallboard	Intact	-0.2	
12	Bathroom	A	Yellow	Wall	Wallboard	Intact	0.1	
13	Kitchen	B	Red	Door	Metal	Intact	-0.1	
14	Kitchen	B	Light Blue	Door Casing	Wood	Intact	-0.2	

+ = positive for lead

## LEAD INSPECTION DATA PAGE

Page 1 of 1

NOTES:

Drawing NOT TO SCALE

ADDRESS 40 Ferry Street (Field Card Location  
40 Ferry Street, Lot # 30)  
Middletown, CT  
Common Areas

DATE September 6, 2005

Sample Number	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
1	1 <sup>st</sup> Floor Landing	B	White	Wall	Wallboard	Intact	-0.1	
2	1 <sup>st</sup> Floor Landing	C	Brown	Riser	Wood	Intact	-0.1	
3	1 <sup>st</sup> Floor Landing	-	White	Ceiling	Wallboard	Intact	0.00	
4	1 <sup>st</sup> Floor Landing	B	Gray	Door	Metal	Intact	0.2	
5	1 <sup>st</sup> Floor Landing	B	Gray	Door Casing	Wood	Intact	-0.1	
6	2 <sup>nd</sup> Floor Stair	C	Gray	Tread	Wood	Poor	0.00	
7	2 <sup>nd</sup> Floor Stair	A	Gray	Window Casing	Wood	Intact	-0.1	
8	3 <sup>rd</sup> Floor Hall	B	Black	Baseboard	Rubber	Intact	0.3	
9	3 <sup>rd</sup> Floor Stair	D	Gray	Rail	Wood	Poor	-0.00	
10	1 <sup>st</sup> Floor Landing	A	Brown	Door	Wood	Poor	0.00	
11	Exterior	A	White	Door	Wood	Poor	0.6	
12	Exterior	A	White	Column	Wood	Poor	0.1	
13	Exterior	A	Stained	Siding	Wood	Intact	0.00	
14	Exterior	A	White	Eave	Wood	Intact	0.2	
15	Exterior	A	Black	Rail	Metal	Poor	-0.1	

+ = positive for lead

**LEAD INSPECTION DATA PAGE**

NOTES:

Drawing NOT TO SCALE

ADDRESS 56 Ferry Street (Front Building)  
 (Field Card Location 54 Ferry Street,  
 Lot # 34)  
 Middletown, CT  
 Unit 1 - Lower Level

DATE September 1, 2005

Sample Number	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
1	Calibration						1.0	
2	Calibration						1.0	
3	Calibration						1.0	
4	Room 1	A	Gray	Wall	Sheetrock	Fair	0.0	
5	Room 1		Beige	Door Frame	Wood	Poor	0.0	
6	Room 1		Beige	Door	Wood	Poor	0.1	
7	Room 1	B	Beige	Window Sill	Wood	Poor	0.1	
8	Room 1		Beige	Window Sash	Wood	Poor	0.1	
9	Room 1		Beige	Trim	Wood	Poor	0.1	
10	Room 1		Gray	Wall	Sheetrock	Poor	0.0	
11	Room 1		Beige	Baseboard	Wood	Poor	0.0	
12	Room 1	A	Beige	Archway	Wood	Poor	0.0	
13	Room 1	-	Beige	Ceiling	Tile	Poor	0.0	
14	Room 1	-	Beige	Ceiling	Wood	Poor	0.0	
15	Room 1	-	Brown	Floor	Wood	Poor	0.1	

+ = positive for lead

**LEAD INSPECTION DATA PAGE**

NOTES:

Drawing NOT TO SCALE

ADDRESS 56 Ferry Street (Front Building)  
 (Field Card Location 54 Ferry Street,  
 Lot # 34)  
 Middletown, CT  
 Unit 1 - Lower Level

DATE September 1, 2005

Sample Number	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
16	Room 2	C	Beige	Wall	Sheetrock	Poor	0.0	
17	Room 2	B	Beige	Door Frame	Wood	Poor	0.1	
18	Room 2	B	Beige	Window Sill	Wood	Poor	0.3	
19	Room 2	B	Beige	Window Sash	Wood	Poor	0.1	
20	Room 2	B	Beige	Window Trim	Wood	Poor	0.2	
21	Room 2	-	White	Ceiling	Tile	Poor	0.0	
22	Room 2	D	Brown	Cabinet	Wood	Good	0.0	
23	Room 3	C	Beige	Cabinet	Wood	Fair	0.2	
24	Room 3	-	White	Ceiling	Tile	Good	0.0	
25	Room 3	B	Brown	Window Sill	Wood	Fair	0.0	
26	Room 3	B	Green	Window Sash	Wood	Poor	0.1	
27	Room 3	B	Brown	Window Trim	Wood	Fair	0.2	
28	Room 3	B	Brown	Wall	Sheetrock	Poor	0.0	
29	Room 3	B	Gray	Wall	Plaster	Poor	4.6	+
30	Room 4	C	White	Window Sill	Wood	Poor	0.1	

+ = positive for lead

**LEAD INSPECTION DATA PAGE**

NOTES:

Drawing NOT TO SCALE

ADDRESS 56 Ferry Street (Front Building)  
 (Field Card Location 54 Ferry Street,  
 Lot # 34)  
 Middletown, CT  
 Unit 1 - Lower Level

DATE September 1, 2005

Sample Number	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
31	Room 4	C	White	Window Sash	Wood	Poor	0.3	
32	Room 4	C	White	Window Trim	Wood	Poor	0.0	
33	Room 4	D	Blue	Wall	Sheetrock	Poor	0.0	
34	Room 4	D	Brown	Baseboard	Wood	Poor	0.3	
35	Room 4	-	White	Ceiling	Plaster	Poor	0.0	
36	Room 5	D	White	Window Sill	Wood	Poor	0.1	
37	Room 5	D	White	Window Sash	Wood	Poor	3.2	+
38	Room 5	D	White	Window Sash	Wood	Poor	2.8	+
39	Room 5	D	White	Window Trim	Wood	Poor	2.0	+
40	Room 5	D	Brown	Wall	Wood Panel	Good	0.1	
41	Room 5	-	Brown	Floor	Wood	Good	0.1	
42	Room 5	-	White	Ceiling	Sheetrock	Fair	0.0	
43	Room 5	A	White	Door Trim	Wood	Poor	0.2	
44	Room 5	A	Brown	Door Frame	Wood	Poor	1.9	+
45	Room 3	B	Brown	Stair	Step	Poor	0.2	

+ = positive for lead



## LEAD INSPECTION DATA PAGE

Page 1 of 3

NOTES:

Drawing NOT TO SCALE

ADDRESS 56 Ferry Street (Front Building)  
 (Field Card Location 54 Ferry Street,  
 Lot # 34)  
 Middletown, CT  
 Unit 2 - Upper Level

DATE September 1, 2005

Sample Number	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
1	Room 1	D	Beige	Door Casing	Wood	Fair	-0.0	
2	Room 1	D	Beige	Wall	Plaster	Poor	1.0	
3	Room 1	D	Beige	Door	Wood	Fair	0.1	
4	Room 1	D	White	Ceiling	Sheetrock	Fair	-0.2	
5	Room 1	B	Beige	Window Sill	Wood	Poor	-0.3	
6	Room 1	B	Beige	Window Casing	Plaster	Poor	-0.1	
7	Room 1	B	Beige	Window Well	Wood	Poor	>9.9	+
8	Room 1	B	Beige	Window Sash	Wood	Poor	-0.1	
9	Room 1	A	Beige	Baseboard	Wood	Fair	-0.1	
10	Room 1	D	Beige	Header	Wood	Fair	0.0	
11	Room 2	D	Beige	Window Sill	Wood	Poor	0.1	
12	Room 2	D	Beige	Window Casing	Wood	Fair	-0.1	
13	Room 2	D	Beige	Window Well	Wood	Poor	0.5	
14	Room 2	D	Beige	Window Sash	Wood	Poor	-0.1	
15	Room 2	B	Beige	Wall	Paneling	Fair	-0.0	

+ = positive for lead

**LEAD INSPECTION DATA PAGE**

NOTES:

Drawing NOT TO SCALE

ADDRESS 56 Ferry Street (Front Building)  
(Field Card Location 54 Ferry Street,  
Lot # 34)  
Middletown, CT  
Unit 2 - Upper Level

DATE September 1, 2005

Sample Number	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
16	Room 3	D	Blue	Wall	Sheetrock	Fair	-0.3	
17	Room 3	A	Blue	Baseboard	Wood	Fair	-0.1	
18	Room 3	A	Blue	Window Sill	Wood	Poor	1.0	
19	Room 3	B	Blue	Window Casing	Wood	Poor	0.4	
20	Room 3	B	Blue	Window Frame	Wood	Poor	0.5	
21	Room 3	B	Red	Floor	Wood	Poor	-0.2	
22	Bathroom	B	White	Window Sill	Wood	Fair	-0.0	
23	Bathroom	B	White	Window Sash	Wood	Poor	2.3	+
24	Bathroom	D	White	Door Casing	Wood	Fair	1.0	+
25	Bathroom	D	White	Door Jamb	Wood	Fair	-0.2	
26	Bathroom	D	White	Door	Wood	Fair	-0.1	
27	Bathroom	D	White	Baseboard	Wood	Fair	-0.2	
28	Room 4	A	Green	Door Casing	Wood	Fair	-0.1	
29	Room 4	A	Beige	Door	Wood	Poor	-0.3	
30	Room 4	B	Green	Wall	Plaster	Poor	-0.2	

+ = positive for lead



## LEAD INSPECTION DATA PAGE

Page 2 of 2

NOTES:

Drawing NOT TO SCALE

ADDRESS 56 Ferry Street  
(Front Building, Field Card Location  
54 Ferry Street, Lot # 37)  
Middletown, CT  
Exterior

DATE September 12, 2005

Sample Number	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
18	Exterior	C	Light Green	Wall	Vinyl	Intact	-0.1	Front
19	Exterior	D	Green	Siding	Wood	Intact	1.3	+ Front
20	Exterior	D	Green	Porch Wall	Wood	Intact	1.4	+ Front
21	Exterior	D	White	Wall	Wood	Poor	3.1	+ Front
22	Exterior	D	Brown	Rail	Wood	Poor	0.2	Front
23	Exterior	D	Red	Window Casing	Wood	Intact	-0.1	Front
24	Exterior	D	White	Window Casing	Wood	Poor	1.6	+ Front
9	Exterior	C	White	Window Casing	Wood	Poor	-0.1	Front
10	Exterior	C	Brown	Lower Wall	Wood	Poor	-0.2	Front
11	Exterior	D	Brown	Column	Wood	Poor	-0.1	Front
12	Exterior	D	Brown	Wall	Wood	Poor	-0.2	Front
13	Exterior	D	White	Window Casing	Wood	Poor	4.9	+ Front
14	Exterior	D	Green	Window Sash	Wood	Poor	1.6	+ Front
15	Exterior	D	Brown	Rail	Wood	Intact	0.1	Front

+ = positive for lead

## LEAD INSPECTION DATA PAGE

Page 1 of 2

NOTES:

Drawing NOT TO SCALE

ADDRESS 56 Ferry Street  
(Rear Building/Bakery, Field Card  
Location 56 Ferry Street, Lot # 33)  
Middletown, CT  
Bakery Unit

DATE September 1, 2005

Sample Number	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
1	Room 1	A	White	Door Jamb	Wood	Fair	-0.2	
2	Room 1	A	White	Wall	Brick	Fair	0.3	
3	Room 1	B	Brown	Wall	Wood	Fair	0.0	
4	Room 1	C	White	Ceiling	Wood	Fair	0.1	
5	Room 1	C	Black	Wall	Wood	Fair	0.1	
6	Room 2	D	White	Wall	Brick	Fair	0.4	
7	Room 2	B	White	Ceiling	Wood	Fair	0.0	
8	Room 2	D	White	Wall	Brick	Fair	-0.2	
9	Room 3	C	White	Wall	Paneling	Fair	0.1	
10	Room 3	D	White	Wall	Brick	Fair	0.3	
11	Room 3	B	White	Wall	Plaster	Fair	-0.1	
12	Room 3	A	Gray	Wall	Plaster	Fair	-0.1	
13	Room 3	D	White	Door Jamb	Wood	Poor	0.0	
14	Room 3	D	Red	Door	Metal	Fair	-0.2	
15	Bathroom	D	Blue	Door	Wood	Fair	2.3	+

+ = positive for lead

**LEAD INSPECTION DATA PAGE**

NOTES:

Drawing NOT TO SCALE

ADDRESS 56 Ferry Street  
(Rear Building/Bakery, Field Card  
Location 56 Ferry Street, Lot # 33)  
Middletown, CT  
Bakery Unit

DATE September 1, 2005

Sample Number	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
16	Bathroom	C	Blue	Wall	Brick	Poor	1.0	+
17	Bathroom	A	White	Door Jamb	Wood	Poor	-0.0	
18	Bathroom	A	Beige	Ceiling	Panel	Poor	0.1	
19	Exterior	A	White	Wall	Wood	Poor	0.2	
20	Exterior	A	White	Window Casing	Wood	Poor	0.3	
21	Exterior	A	White	Window Sill	Wood	Poor	0.3	
22	Exterior	A	White	Wall	Brick	Poor	0.3	
23	Exterior	D	Red	Ceiling	Wood	Poor	0.1	
24	Exterior	D	Red	Over Hang	Wood	Poor	0.0	
25	Exterior	D	Red	Door	Wood	Poor	0.1	
26	Exterior	D	White	Support Column	Wood	Poor	0.1	
27	Exterior	D	Brown	Door	Wood	Poor	0.1	
28	Exterior	D	Brown	Door Casing	Wood	Poor	-0.1	

+ = positive for lead

## LEAD INSPECTION DATA PAGE

Page 1 of 3

NOTES:

Drawing NOT TO SCALE

ADDRESS 56 Ferry Street  
(Rear Building/Bakery, Field Card  
Location 56 Ferry Street, Lot # 33)  
Middletown, CT  
Unit 1

DATE September 1, 2005

Sample Number	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
1	Room 1	A	White	Wall	Plaster	Fair	-0.4	
2	Room 1	A	Brown	Door	Wood	Fair	0.0	
3	Room 1	D	White	Door Jamb	Wood	Poor	2.3	+
4	Room 1	D	White	Door Casing	Wood	Poor	0.2	
5	Room 1	D	Beige	Window Sill	Wood	Fair	0.0	
6	Room 1	D	Beige	Window Sash	Wood	Poor	1.0	+
7	Room 1	D	Beige	Window Well	Wood	Poor	1.0	+
8	Room 1	D	White	Wall	Plaster	Poor	0.0	
9	Room 1	A	White	Baseboard	Wood	Fair	0.2	
10	Room 2	B	White	Wall	Plaster	Fair	0.3	
11	Room 2	A	White	Window Sill	Wood	Poor	0.2	
12	Room 2	A	White	Window Sash	Wood	Poor	2.8	+
13	Room 2	D	White	Floor	Wood	Poor	0.1	
14	Room 2	B	Beige	Baseboard	Wood	Fair	0.0	
15	Room 2	B	Beige	Ceiling	Plaster	Fair	0.0	

+ = positive for lead

## LEAD INSPECTION DATA PAGE

Page 2 of 3

NOTES:

Drawing NOT TO SCALE

ADDRESS 56 Ferry Street  
(Rear Building/Bakery, Field Card  
Location 56 Ferry Street, Lot # 33)  
Middletown, CT  
Unit 1

DATE September 1, 2005

Sample Number	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
16	Room 3	C	Beige	Door Casing	Wood	Fair	0.2	
17	Room 3	B	White	Wall	Plaster	Fair	0.1	
18	Room 3	B	White	Window Sill	Wood	Poor	0.3	
19	Room 3	B	White	Window Sash	Wood	Poor	0.3	
20	Room 3	B	White	Window Well	Wood	Poor	6.2	+
21	Room 3	B	White	Baseboard	Wood	Fair	-0.3	
22	Bathroom	A	White	Door Casing	Wood	Fair	0.1	
23	Bathroom	A	Beige	Door	Wood	Fair	0.3	
24	Bathroom	B	White	Wall	Plaster	Fair	0.0	
25	Bathroom	B	White	Window Well	Wood	Poor	5.7	+
26	Bathroom	D	White	Baseboard	Wood	Fair	0.2	
27	Room 4	C	Gray	Door Casing	Wood	Fair	0.0	
28	Room 4	C	Gray	Door	Wood	Fair	0.1	
29	Room 4	D	Yellow	Window Well	Wood	Poor	2.9	+
30	Room 4	D	Gray	Window Casing	Wood	Poor	0.1	

+ = positive for lead



## LEAD INSPECTION DATA PAGE

Page 1 of 3

NOTES:

Drawing NOT TO SCALE

ADDRESS 56 Ferry Street  
(Rear Building/Bakery, Field Card  
Location 56 Ferry Street, Lot # 33)  
Middletown, CT  
Unit 2

DATE September 1, 2005

Sample Number	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
1	Room 1	D	White	Window Well	Wood	Poor	2.3	+
2	Room 1	D	White	Window Sash	Wood	Poor	3.8	+
3	Room 1	D	Gray	Ceiling	Plaster	Poor	1.0	+
4	Room 1	A	Green	Wall	Plaster	Poor	3.5	+
5	Room 1	A	White	Baseboard	Wood	Fair	0.2	
6	Room 1	D	White	Door	Wood	Fair	-0.1	
7	Room 2	A	Beige	Wall	Plaster	Fair	0.0	
8	Room 2	A	White	Window Well	Wood	Poor	1.8	+
9	Room 2	A	White	Window Sash	Wood	Poor	2.8	+
10	Room 2	B	White	Baseboard	Wood	Poor	0.2	
11	Room 2	B	White	Door	Wood	Poor	0.0	
12	Room 2	C	White	Door Casing	Wood	Poor	-0.3	
13	Room 3	B	Brown	Wall	Plaster	Poor	-0.3	
14	Room 3	B	White	Window Well	Wood	Poor	3.5	+
15	Room 3	C	White	Baseboard	Wood	Fair	0.0	

+ = positive for lead

**LEAD INSPECTION DATA PAGE**

NOTES:

Drawing NOT TO SCALE

ADDRESS 56 Ferry Street  
(Rear Building/Bakery, Field Card  
Location 56 Ferry Street, Lot # 33)  
Middletown, CT  
Unit 4

DATE September 1, 2005

Sample Number	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
16	Room 3	C	Brown	Floor	Wood	Poor	0.0	
17	Bathroom	A	White	Door Casing	Wood	Poor	0.1	
18	Bathroom	A	White	Door	Wood	Poor	0.2	
19	Bathroom	B	Green	W-Plaster	Plaster	Poor	0.2	
20	Bathroom	B	White	Door Casing	Wood	Poor	0.0	
21	Bathroom	B	White	Window Sill	Wood	Poor	0.0	
22	Bathroom	B	White	Window Sash	Wood	Poor	0.2	
23	Bathroom	B	White	Window Well	Wood	Poor	2.2	+
24	Room 4	C	White	Ceiling	Plaster	Fair	0.4	
25	Room 4	C	White	Door Casing	Wood	Poor	0.0	
26	Room 4	C	White	Door	Wood	Poor	0.3	
27	Room 4	D	White	Baseboard	Wood	Poor	0.2	
28	Room 4	D	Brown	Floor	Wood	Poor	0.0	
29	Room 4	D	White	Window Well	Wood	Poor	4.1	+
30	Calibration						1.0	

+ = positive for lead



**LEAD INSPECTION DATA PAGE**

NOTES:

Drawing NOT TO SCALE

ADDRESS 56 Ferry Street (Rear Building/Bakery, Field Card Location 56 Ferry Street, Lot # 33) Middletown, CT Exterior

DATE September 12, 2005

Sample Number	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
1	Exterior	D	White	Upper Wall	Brick	Intact	-0.1	Rear
2	Exterior	D	Gray	Lower Wall	Brick	Intact	-0.1	Rear
3	Exterior	A	White	Lower Wall	Wood	Intact	0.00	Rear
4	Exterior	A	White	Window Casing	Wood	Intact	-0.1	Rear
5	Exterior	D	Brown	Window Frame	Metal	Poor	0.1	Rear
6	Exterior	D	Brown	Window Header	Metal	Intact	0.2	Rear Bldg.
7	Exterior	D	White	Column	Wood	Poor	-0.1	Rear
8	Exterior	D	White	Window Header	Metal	Poor	-0.2	Rear
16	Exterior	A	Brown	Wall	Wood	Intact	0.1	Rear
17	Exterior	B	Brown	Window Header	Metal	Poor	-0.3	Rear
25	Exterior	D	Brown	Window Lintel	Metal	Poor	-0.2	Rear
26	Exterior	A	White	Window Sill	Wood	Intact	0.6	Rear
27	Exterior	A	White	Window Sill	Wood	Poor	4.3	+ Rear
28	Exterior	A	White	Window Sill	Wood	Intact	0.0	Rear
29	Exterior	C	White	Window Sill	Wood	Intact	0.10	Rear

+ = positive for lead

**LEAD INSPECTION DATA PAGE**

NOTES:

Drawing NOT TO SCALE

ADDRESS 58 Ferry Street  
(Field Card Location 58 Ferry Street,  
Lot # 33)  
Middletown, CT  
2<sup>nd</sup> Floor Rear Apartment

DATE September 9, 2005

Sample Number	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
1	Calibration						1.0	
2	Calibration						1.0	
3	Calibration						1.0	
4	Exterior	B	Tan	Siding	Wood	Intact	>9.9	+
5	Exterior	B	Tan	Window Casing	Wood	Intact	1.0	+
6	Exterior	B	Green	Window Casing	Wood	Poor	2.6	+
7	Kitchen	-	White	Ceiling	Plaster	Intact	0.6	
8	Kitchen	A	White	Wall	Plaster	Intact	2.6	+
9	Kitchen	A	White	Door Casing	Wood	Intact	0.2	
10	Dining Room	A	White	Wall	Plaster	Intact	0.1	
11	Dining Room	D	White	Baseboard	Wood	Intact	>9.9	+
12	Bathroom	B	White	Door	Wood	Intact	>9.9	+
13	Bathroom	B	White	Door Casing	Wood	Intact	>9.9	+
14	Bathroom	A	White	Wall	Plaster	Intact	0.2	
15	Living Room	D	White	Window Sill	Wood	Intact	0.1	

+ = positive for lead

**LEAD INSPECTION DATA PAGE**

NOTES:

Drawing NOT TO SCALE

ADDRESS 58 Ferry Street  
 (Field Card Location 58 Ferry Street,  
 Lot # 33)  
 Middletown, CT  
 2<sup>nd</sup> Floor Rear Apartment

DATE September 9, 2005

Sample Number	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
16	Living Room	C	White	Door	Wood	Intact	0.2	
17	Living Room	C	White	Door Casing	Wood	Intact	0.2	
18	Living Room	C	White	Radiator	Metal	Intact	0.1	
19	Living Room	C	White	Wall	Plaster	Intact	-0.3	
20	Living Room	D	White	Window Sash	Vinyl	Intact	0.00	
21	Exterior	B	Gray	Step	Wood	Intact	-0.3	
22	Exterior	B	Green	Door	Wood	Intact	-0.1	
23	Exterior	B	Tan	Door Casing	Wood	Intact	-0.2	
24	Exterior	A	Green	Door	Wood	Intact	-0.2	
25	Exterior	A	White	Door Casing	Wood	Intact	-0.00	

+ = positive for lead

## LEAD INSPECTION DATA PAGE

Page 1 of 3

NOTES:

Drawing NOT TO SCALE

ADDRESS 58 Ferry Street  
(Field Card Location 58 Ferry Street,  
Lot # 33)  
Middletown, CT  
2<sup>nd</sup> Floor Front Apartment

DATE September 9, 2005

Sample Number	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
1	Living Room	B	White	Wall	Plaster	Intact	-0.2	
2	Living Room	B	White	Door	Wood	Intact	-0.1	
3	Living Room	B	White	Door Casing	Wood	Intact	-0.1	
4	Living Room	A	White	Window Casing	Wood	Intact	-0.1	
5	Living Room	-	White	Ceiling	Plaster	Intact	-0.2	
6	Dining Room	B	White	Door	Wood	Intact	8.3	+
7	Dining Room	B	White	Door Casing	Wood	Intact	>9.9	+
8	Dining Room	B	White	Baseboard	Wood	Intact	>9.9	+
9	Kitchen	A	White	Wall	Plaster	Intact	-0.2	
10	Kitchen	D	White	Door	Wood	Intact	>9.9	+
11	Kitchen	D	White	Door Casing	Wood	Intact	>9.9	+
12	Kitchen	D	White	Window Casing	Wood	Intact	>9.9	+
13	Kitchen	D	White	Window Sash	Vinyl	Fair	0.00	
14	Bathroom	D	White	Wall	Plaster	Intact	0.2	
15	Bedroom 2	A	Blue	Wall	Plaster	Intact	4.6	+

+ = positive for lead

**LEAD INSPECTION DATA PAGE**

NOTES:

Drawing NOT TO SCALE

ADDRESS 58 Ferry Street  
 (Field Card Location 58 Ferry Street,  
 Lot # 33)  
 Middletown, CT  
 2<sup>nd</sup> Floor Front Apartment

DATE September 9, 2005

Sample Number	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
16	Bedroom 2	A	White	Door Casing	Wood	Intact	7.1	+
17	Bedroom 2	B	White	Radiator	Metal	Intact	-0.1	
18	Bedroom 1	B	Purple	Wall	Plaster	Intact	5.6	+
19	Stairwell	B	Stained	Window Casing	Wood	Intact	-0.1	
20	Stairwell	-	Red	Tread	Wood	Poor	-0.2	
21	Stairwell	-	Red	Tread	Cement	Poor	-0.1	
22	Exterior	C	Gray	Step	Wood	Intact	0.1	
23	Exterior	C	Gray	Rail	Wood	Intact	-0.1	
24	Exterior	C	Tan	Siding	Wood	Intact	-0.1	
25	Exterior	C	Tan	Window Sill	Wood	Intact	0.6	
26	Exterior	C	Gray	Hatch	Metal	Poor	-0.3	
27	Exterior	B	Tan	Window Casing	Wood	Intact	0.5	
28	Exterior	B	Green	Window Frame	Wood	Poor	0.3	
29	Exterior	A	White	Window Sash	Vinyl	Intact	0.00	
30	Exterior	A	White	Door Lintel	Metal	Intact	3.1	+

+ = positive for lead



## LEAD INSPECTION DATA PAGE

Page 1 of 3

NOTES:

Drawing NOT TO SCALE

ADDRESS 60 Ferry Street  
(Field Card Location 60 Ferry Street,  
Lot # 36)  
Middletown, CT  
2<sup>nd</sup> Floor Front Apartment

DATE September 9, 2005

Sample Number	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
1	Room 1	A	Blue	Wall	Plaster	Intact	1.1	+
2	Room 1	A	White	Window Casing	Wood	Intact	0.1	
3	Room 1	A	White	Window Sash	Wood	Intact	-0.1	
4	Room 1	A	White	Baseboard	Wood	Intact	-0.2	
5	Room 1	-	White	Ceiling	Plaster	Intact	1.0	+
6	Room 1	C	White	Door Casing	Wood	Intact	-0.1	
7	Room 2	-	Gray	Floor	Wood	Poor	-0.3	
8	Room 2	B	White	Radiator	Metal	Poor	-0.1	
9	Room 2	D	White	Door	Wood	Poor	>9.9	+
10	Room 4	A	Tan	Lower Wall	Plaster	Intact	-0.1	
11	Room 4	A	White	Upper Wall	Plaster	Intact	-0.0	
12	Room 4	-	Gray	Floor	Wood	Poor	-0.1	
13	Room 4	-	White	Ceiling	Plaster	Intact	0.6	
14	Room 3	D	White	Window Sill	Wood	Poor	-0.1	
15	Room 3	C	White	Door	Wood	Intact	>9.9	+

+ = positive for lead

## LEAD INSPECTION DATA PAGE

Page 2 of 3

NOTES:

Drawing NOT TO SCALE

ADDRESS 60 Ferry Street  
(Field Card Location 60 Ferry Street,  
Lot # 36)  
Middletown, CT

DATE September 9, 2005

2<sup>nd</sup> Floor Front Apartment/Exterior

Sample Number	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
16	Kitchen	D	White	Wall	Plaster	Intact	7.0	+
17	Kitchen	D	White	Window Sash	Wood	Intact	0.1	
18	Kitchen	-	White	Ceiling	Plaster	Intact	0.2	
19	Bathroom	C	Tan	Wall	Plaster	Intact	1.7	+
20	Attic	C	White	Wall	Wood	Intact	6.2	+
21	Attic	C	Brown	Step	Wood	Intact	0.2	
22	Exterior	C	Gray	Lower Wall	Cement	Intact	0.1	
23	Exterior	D	White	Siding	Wood	Poor	>9.9	+ under siding
24	Exterior	D	White	Door	Metal	Intact	0.1	
25	Exterior	D	Brown	Window Frame	Wood	Poor	4.6	+
26	Exterior	C	Brown	Stair	Wood	Intact	0.00	
27	Exterior	D	White	Door	Metal	Intact	0.1	
28	Exterior	D	White	Door Casing	Wood	Intact	0.00	
29	Exterior	C	White	Siding	Wood	Poor	>9.9	+
30	Exterior	D	Brown	Window Frame	Wood	Poor	3.2	+

+ = positive for lead

**LEAD INSPECTION DATA PAGE**

NOTES:

Drawing NOT TO SCALE

ADDRESS 60 Ferry Street  
(Field Card Location 60 Ferry Street,  
Lot # 36)  
Middletown, CT

DATE September 12, 2005

Exterior

Sample Number	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
31	Exterior	D	Black	Rail	Metal	Poor	0.1	
32	Exterior	D	White	Door Casing	Wood	Poor	2.1	+
33	Exterior	D	White	Door	Wood	Poor	0.2	
34	Exterior	D	Red/Brown	Hatch	Metal	Poor	0.3	
35	Exterior	D	White	Window Casing	Wood	Poor	6.1	+
36	Exterior	D	Red	Window Frame	Wood	Intact	0.1	
37	Exterior	A	Yellow	Siding	Metal	Intact	-0.2	
38	Exterior	A	White	Window Sill	Wood	Poor	>9.9	+
39	Exterior	B	Brown	Rail	Wood	Poor	0.00	
40	Exterior	A	White	Door	Wood	Poor	-0.2	

+ = positive for lead

**LEAD INSPECTION DATA PAGE**

NOTES:

Drawing NOT TO SCALE

ADDRESS 64 Ferry Street (Field Card Location  
66 Ferry Street, Lot # 37A)  
Middletown, CT  
Garage

DATE September 9, 2005

Sample Number	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
1	Garage	A	White	Wall	Brick	Intact	-0.1	
2	Office	A	Gray	Door	Metal	Intact	0.1	
3	Office	A	Light Blue	Door Casing	Wood	Intact	-0.2	
4	Storage Room	A	Light Blue	Door	Wood	Intact	4.6	+
5	Storage Room	D	White	Wall	Wood	Intact	>9.9	+
6	Storage Room	A	White	Door	Metal	Intact	-0.2	
7	Storage Room	A	Green	Window Frame	Metal	Poor	>9.9	+
8	Bathroom	A	Light Blue	Door	Wood	Poor	>9.9	+
9	Bathroom	A	Light Blue	Door Casing	Wood	Intact	-0.1	
10	Bathroom	B	Light Blue	Wall	Wallboard	Poor	0.0	
11	Break Room	D	Green	Door Casing	Wood	Poor	>9.9	+
12	Break Room	D	Blue	Door	Wood	Poor	4.6	+
13	Garage	C	White	Upper Wall	Brick	Poor	-0.2	
14	Garage	C	White	Lower Wall	Cement	Poor	0.1	
15	Garage	C	Brown	Window Frame	Metal	Poor	-0.2	

+ = positive for lead

**LEAD INSPECTION DATA PAGE**

NOTES:

Drawing NOT TO SCALE

ADDRESS 64 Ferry Street (Field Card Location  
66 Ferry Street, Lot # 37A)  
Middletown, CT  
Garage

DATE September 9, 2005

Sample Number	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
16	Garage	D	Brown	Window Frame	Metal	Poor	-0.2	
17	Garage	-	Brown	Ceiling Truss	Metal	Poor	0.6	
18	Exterior	A	Brown	Door Casing	Wood	Intact	-0.4	
19	Exterior	A	Brown	Window Frame	Metal	Poor	-0.1	
20	Exterior	A	Gray	Door	Metal	Poor	-0.1	
21	Exterior	A	Brown	Door Casing	Wood	Intact	0.1	
22	Exterior	B	White	Wall	Brick	Intact	-0.0	
23	Exterior	C	Brown	Window Frame	Metal	Poor	-0.2	
24	Calibration						0.9	
25	Calibration						1.0	
26	Calibration						1.0	

+ = positive for lead

## LEAD INSPECTION DATA PAGE

Page 1 of 2

NOTES:

Drawing NOT TO SCALE

ADDRESS 66 Ferry Street (Field Card Location  
64 Ferry Street, Lot # 37)  
1<sup>st</sup> Floor Rear Apartment

DATE September 9, 2005

Sample Number	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
1	Kitchen	-	White	Ceiling	Plaster	Intact	-0.2	
2	Kitchen	C	White	Wall	Plaster	Intact	-0.1	
3	Hall	D	Blue	Wall	Wood	Intact	0.1	
4	Hall	B	Blue	Wall	Wallboard	Intact	-0.1	
5	Bathroom	-	White	Ceiling	Plaster	Intact	-0.1	
6	Bathroom	D	White	Wall	Wood	Intact	0.2	
7	Bathroom	B	White	Window Casing	Wood	Intact	-0.1	
8	Bathroom	D	Tan	Radiator	Metal	Intact	0.1	
9	Bathroom	C	White	Window Sash	Wood	Intact	0.1	
10	Bathroom	C	White	Window Casing	Wood	Intact	0.0	
11	Bedroom 3	B	White	Door	Wood	Intact	-0.1	
12	Bedroom 3	B	White	Door Casing	Wood	Intact	-0.1	
13	Living Room	B	White	Wall	Wood	Intact	-0.3	
14	Living Room	-	White	Ceiling	Wallboard	Intact	-0.1	
15	Bedroom 1	D	White	Wall	Wood	Intact	-0.3	

+ = positive for lead



**LEAD INSPECTION DATA PAGE**

NOTES:

Drawing NOT TO SCALE

ADDRESS 66 Ferry Street (Field Card Location  
64 Ferry Street, Lot # 37)  
Apartment 2E

DATE September 9, 2005

Sample Number	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
1	Bathroom	A	White	Wall	Plaster	Intact	-0.3	
2	Bathroom	-	White	Ceiling	Plaster	Intact	-0.2	
3	Bathroom	B	White	Door Casing	Wood	Intact	0.4	
4	Kitchen	C	Gray	Door	Metal	Intact	-0.1	
5	Kitchen	A	White	Wall	Plaster	Intact	-0.2	
6	Kitchen	-	White	Ceiling	Plaster	Intact	-0.2	
7	Kitchen	A	White	Baseboard	Wood	Intact	0.1	
8	Living Room	D	White	Window Sill	Wood	Intact	-0.1	
9	Living Room	D	White	Window Sash	Vinyl	Intact	0.1	
10	Living Room	D	White	Radiator	Metal	Intact	-0.1	
11	Bedroom	C	White	Door	Wood	Intact	-0.3	
12	Bedroom	C	White	Door Casing	Wood	Intact	-0.1	
13	Bedroom	D	White	Wall	Plaster	Intact	-0.2	
14	Bedroom	-	White	Ceiling	Plaster	Intact	-0.3	

+ = positive for lead

## LEAD INSPECTION DATA PAGE

Page 1 of 1

NOTES:

Drawing NOT TO SCALE

ADDRESS 66 Ferry Street (Field Card Location  
64 Ferry Street, Lot # 37)  
Apartment 2W

DATE September 9, 2005

Sample Number	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
1	Bathroom	D	White	Door	Wood	Intact	-0.1	
2	Bathroom	D	White	Door Casing	Wood	Intact	-0.2	
3	Bathroom	C	White	Wall	Plaster	Intact	-0.1	
4	Kitchen	D	White	Wall	Plaster	Intact	0.1	
5	Kitchen	-	White	Ceiling	Plaster	Intact	0.2	
6	Kitchen	A	White	Baseboard	Wood	Intact	-0.1	
7	Kitchen	C	White	Cabinet	Wood	Intact	-0.0	
8	Living Room	B	White	Window Sill	Wood	Intact	-0.2	
9	Living Room	B	White	Radiator	Metal	Intact	-0.2	
10	Living Room	B	White	Wall	Plaster	Intact	-0.2	
11	Bedroom	A	White	Window Casing	Wood	Intact	0.1	
12	Bedroom	-	White	Ceiling	Plaster	Intact	-0.1	

+ = positive for lead

**LEAD INSPECTION DATA PAGE**

NOTES:

Drawing NOT TO SCALE


<b>ADDRESS</b> 66 Ferry Street, (Field Card Location 64 Ferry Street, Lot # 37) Middletown, CT Exterior	<b>DATE</b> September 12, 2005
--	--------------------------------

Sample Number	Location	Side	Color	Surface Type	Substrate	Paint Condition	Results Mg/cm <sup>2</sup>	Comments
1	Exterior	A	White	Wall	Cement	Intact	0.3	
2	Exterior	A	White	Window Casing	Wood	Poor	2.6	+
3	Exterior	A	White	Window Sash	Metal	Intact	-0.1	
4	Exterior	B	White	Wall	Cement Block	Intact	0.00	
5	Exterior	B	White	Window Sash	Wood	Poor	1.4	+
6	Exterior	B	White	Wall	Cement	Poor	-0.1	
7	Exterior	C	White	Wall	Cement	Intact	0.2	
8	Exterior	C	Brown	Rail	Wood	Intact	-0.1	
9	Exterior	C	White	Door	Metal	Intact	-0.1	
10	Exterior	C	White	Door Casing	Wood	Poor	0.1	
11	Calibration						1.0	
12	Calibration						1.0	
13	Calibration						1.0	


+ = positive for lead

**APPENDIX B**


**DIAGRAMS**




UNIT 1E  
36 HERRY STREET (HELD CARD LOCATION 3 4 HERRY STREET  
LOT # 29 )




APARTMENT 2E  
36 FERRY STREET (HELD CARD LOCATION 3 FERRY  
STREET, LOT # 29)




Apartment 2W  
36 Ferry Street (Field Card Location 34 Ferry Street, Lot 29)




APARTMENT 3W  
36 FERRY STREET (FIELD CARD LOCATION 34 FERRY STREET, LOT #29)




40 Ferry Street- Unit 1  
Lot # 30




40 Ferry Street- Unit 4  
Lot # 30




40 Ferry Street- Unit 5  
Lot # 40




40 Ferry Street- Unit 8  
Lot # 30




40 Ferry Street- Unit 9  
Lot # 30




Unit 1 - Lower Level  
56 Ferry Street Front Building  
(Field Card Location 54 Ferry Street, Lot # 34)




Unit 2 Upper Level  
56 Ferry Street Front Building  
(Field Card Location 54 Ferry Street, Lot # 37)




56 Ferry Street  
Rear Building/Bakery  
Bakery Unit  
Lot # 33




56 Ferry Street  
Rear Building/Bakery  
Unit 1  
Lot # 33




56 Ferry Street  
Rear Building/Bakery  
Unit 2  
Lot # 33




56 Ferry Street  
Rear Building/Bakery  
Unit 4  
Lot # 33




58 FERRY STREET, 2ND FLOOR FRONT  
LOT #33




58 FERRY STREET, 2ND FLOOR REAR  
LOT # 33




60 FERRY STREET, 2nd FLOOR FRONT  
LOT #36






FIRST FLOOR  
REAR APARTMENT  
66 FERRY STREET (HELD CARD LOCATION 64 FERRY STREET)  
LOT #37



APARTMENT 2E  
66 FERRY STREET (HELD CARD LOCATION 64 FERRY STREET, LOT #37)



APARTMENT 2W  
66 FERRY STREET (HELD CARD LOCATION 6-FERRY STREET, LOT #37)